STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155684	A. BUILDING 01 B. WING _____	08/14/2012

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
SOUTHFIELD VILLAGE	6450 MIAMI CIR SOUTH BEND, IN 46614

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health. Survey Date: 08/14/12 Facility Number: 002662 Provider Number: 155684 AIM Number: 200315930 Surveyor: Robert Booher, Life Safety Code Specialist At this Quality Assurance Walk-thru survey, Southfield Village was found in compliance with 410 IAC 16.2-3.1-19(ff). This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The building was constructed in 2000 and is adjacent to an assisted living unit and separated by a two hour rated fire wall. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and hard wired smoke detectors in the resident sleeping rooms which activate at the nurses' station. The facility has a capacity of 60 and had a census of 49 at the time of this survey. The facility was in compliance with state law in regard to sprinkler coverage and smoke detector coverage. All areas where residents have customary access were sprinklered and all areas providing facility services were sprinklered.	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155684	A. BUILDING 01 B. WING _____	08/14/2012

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
SOUTHFIELD VILLAGE	6450 MIAMI CIR SOUTH BEND, IN 46614

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 1 Quality Review by Dennis Austill, Life Safety Code Supervisor on 08/14/12.	K 000		